

Winstone Aggregates -
 Otaki/Waikanae/Paraparamu
 Main Road
 Otaki
 Attention: Wayne Read

Analytical Report

Report Number: 20/52258

Issue: 1
 02 October 2020

Sample	Site	Map Ref.	Date Sampled	Date Received	Order No.
20/52258-01	Bore water		29/09/2020 12:10	29/09/2020 14:16	0
Notes: 72 Te Roto Bore - Otaki					
Test	Result	Units	Test Date	Signatory	
0001 pH	6.2		29/09/2020	Marylou Cabral KTP	
0052 Alkalinity - Total	18	g CaCO3/m ³	29/09/2020	Marylou Cabral KTP	
0055 Conductivity at 25°C	10.0	mS/m	29/09/2020	Marylou Cabral KTP	
0602 Chloride	10.6	g/m ³	28/09/2020	Shanel Kumar KTP	
0605 Nitrate - Nitrogen	0.83	g/m ³	28/09/2020	Shanel Kumar KTP	
1642 Total Hardness	27	g CaCO3/m ³	01/10/2020	Shuyu Zhao KTP	
1800 Aluminium - Dissolved	< 0.005	g/m ³	01/10/2020	Shuyu Zhao KTP	
1810 Calcium - Dissolved	7.97	g/m ³	01/10/2020	Shuyu Zhao KTP	
1819 Iron - Dissolved	0.017	g/m ³	01/10/2020	Shuyu Zhao KTP	
1822 Magnesium - Dissolved	1.71	g/m ³	01/10/2020	Shuyu Zhao KTP	
1823 Manganese - Dissolved	0.009	g/m ³	01/10/2020	Shuyu Zhao KTP	
5007 TPH C7 - C9	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5010 TPH C10 - C12	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5012 TPH C13 - C19	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5015 TPH C20 - C26	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5021 TPH C27 - C37	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5040 Maximum TPH Content	< 0.5 *	mg/L	29/09/2020	Dr Alan Stanley KTP	
M0102 Faecal Coliforms	< 1	cfu/100ml	29/09/2020	Maria Norris KTP	
M0104 E. coli	< 1	cfu/100mL	29/09/2020	Maria Norris KTP	
P1859 Sample Filtration	Completed		30/09/2020	Stephen Hutton .	

Sample	Site	Map Ref.	Date Sampled	Date Received	Order No.
20/52258-02	Bore water		29/09/2020 12:45	29/09/2020 14:16	0
Notes: Winstone Site Bore - Otaki					
Test	Result	Units	Test Date	Signatory	
0001 pH	6.2		29/09/2020	Marylou Cabral KTP	
0052 Alkalinity - Total	17	g CaCO3/m ³	29/09/2020	Marylou Cabral KTP	
0055 Conductivity at 25°C	9.7	mS/m	29/09/2020	Marylou Cabral KTP	
0602 Chloride	10.1	g/m ³	28/09/2020	Shanel Kumar KTP	
0605 Nitrate - Nitrogen	0.74	g/m ³	28/09/2020	Shanel Kumar KTP	
1642 Total Hardness	25	g CaCO3/m ³	01/10/2020	Shuyu Zhao KTP	
1800 Aluminium - Dissolved	< 0.005	g/m ³	01/10/2020	Shuyu Zhao KTP	
1810 Calcium - Dissolved	7.55	g/m ³	01/10/2020	Shuyu Zhao KTP	
1819 Iron - Dissolved	< 0.005	g/m ³	01/10/2020	Shuyu Zhao KTP	
1822 Magnesium - Dissolved	1.58	g/m ³	01/10/2020	Shuyu Zhao KTP	
1823 Manganese - Dissolved	< 0.005	g/m ³	01/10/2020	Shuyu Zhao KTP	
5007 TPH C7 - C9	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5010 TPH C10 - C12	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5012 TPH C13 - C19	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5015 TPH C20 - C26	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5021 TPH C27 - C37	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5040 Maximum TPH Content	< 0.5 *	mg/L	29/09/2020	Dr Alan Stanley KTP	
M0102 Faecal Coliforms	< 1	cfu/100ml	29/09/2020	Maria Norris KTP	
M0104 E. coli	< 1	cfu/100mL	29/09/2020	Maria Norris KTP	



Wellington
 85 Port Road, Seaview
 Lower Hutt 5045
 Phone: (04) 576-5016

Rolleston
 43 Detroit Drive
 Rolleston 7675
 Phone: (03) 343-5227

Dunedin
 16 Lorne Street
 South Dunedin 9012
 Phone: (03) 972-7963

Sample	Site	Map Ref.	Date Sampled	Date Received	Order No.
20/52258-02	Bore water		29/09/2020 12:45	29/09/2020 14:16	0
Notes: Winstone Site Bore - Otaki					
Test	Result	Units	Test Date	Signatory	
P1859 Sample Filtration	Completed		30/09/2020	Stephen Hutton .	

Sample	Site	Map Ref.	Date Sampled	Date Received	Order No.
20/52258-03	Surface Water		29/09/2020 12:25	29/09/2020 14:16	0
Notes: Winstone Site Pond - Otaki					
Test	Result	Units	Test Date	Signatory	
0001 pH	7.2		29/09/2020	Marylou Cabral KTP	
0052 Alkalinity - Total	17	g CaCO3/m ³	29/09/2020	Marylou Cabral KTP	
0055 Conductivity at 25°C	7.6	mS/m	29/09/2020	Marylou Cabral KTP	
0602 Chloride	7.93	g/m ³	01/10/2020	Shanel Kumar KTP	
0605 Nitrate - Nitrogen	0.21	g/m ³	01/10/2020	Shanel Kumar KTP	
1642 Total Hardness	19	g CaCO3/m ³	01/10/2020	Shuyu Zhao KTP	
1800 Aluminium - Dissolved	0.017	g/m ³	01/10/2020	Shuyu Zhao KTP	
1810 Calcium - Dissolved	5.62	g/m ³	01/10/2020	Shuyu Zhao KTP	
1819 Iron - Dissolved	0.008	g/m ³	01/10/2020	Shuyu Zhao KTP	
1822 Magnesium - Dissolved	1.22	g/m ³	01/10/2020	Shuyu Zhao KTP	
1823 Manganese - Dissolved	< 0.005	g/m ³	01/10/2020	Shuyu Zhao KTP	
5007 TPH C7 - C9	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5010 TPH C10 - C12	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5012 TPH C13 - C19	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5015 TPH C20 - C26	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5021 TPH C27 - C37	< 0.1	mg/L	29/09/2020	Dr Alan Stanley KTP	
5040 Maximum TPH Content	< 0.5 *	mg/L	29/09/2020	Dr Alan Stanley KTP	
M0102 Faecal Coliforms	56	cfu/100ml	29/09/2020	Maria Norris KTP	
M0104 E. coli	56	cfu/100mL	29/09/2020	Juana Tamayo KTP	
P1859 Sample Filtration	Completed		30/09/2020	Stephen Hutton .	

Comments:

* Not an accredited test.

Sampled by customer using ELS approved containers.

All samples analysed as we receive them. Delivery was within the correct time and temperature conditions.

Test Methodology:

Test	Methodology	Detection Limit
pH	Dedicated pH meter following APHA Online Edition Method 4500-H B.	0.1
Alkalinity - Total	APHA Online Edition Method 2320 B	1 g CaCO3/m ³
Conductivity at 25°C	APHA Online Edition Method 2510 B.	0.1 mS/m
Chloride	Ion Chromatography following APHA 4110B.	0.02 g/m ³
Nitrate - Nitrogen	Ion Chromatography following APHA 4110B.	0.01 g/m ³
Total Hardness	ICP-OES following APHA Online Edition Method 3120 B (modified).	1 g CaCO3/m ³
Aluminium - Dissolved	ICP-OES following APHA Online Edition Method 3120 B (modified).	0.005 g/m ³
Calcium - Dissolved	ICP-OES following APHA Online Edition Method 3120 B (modified).	0.01 g/m ³
Iron - Dissolved	ICP-OES following APHA Online Edition Method 3120 B (modified).	0.005 g/m ³
Magnesium - Dissolved	ICP-OES following APHA Online Edition Method 3120 B (modified).	0.01 g/m ³
Manganese - Dissolved	ICP-OES following APHA Online Edition Method 3120 B (modified).	0.005 g/m ³
TPH C7 - C9	Total Petroleum Hydrocarbon performed by GC-FID.	0.1 mg/L
TPH C10 - C12	Total Petroleum Hydrocarbon performed by GC-FID	0.1 mg/L
TPH C13 - C19	Total Petroleum Hydrocarbon performed by GC-FID	0.1 mg/L
TPH C20 - C26	Total Petroleum Hydrocarbon performed by GC-FID	0.1 mg/L
TPH C27 - C37	Total Petroleum Hydrocarbon performed by GC-FID	0.1 mg/L



Wellington
85 Port Road, Seaview
Lower Hutt 5045
Phone: (04) 576-5016

Rolleston
43 Detroit Drive
Rolleston 7675
Phone: (03) 343-5227

Dunedin
16 Lorne Street
South Dunedin 9012
Phone: (03) 972-7963

Page 2 of 3
Report Number: 20/52258-1 ELS

02 October 2020 16:03:38

Test	Methodology	Detection Limit
Maximum TPH Content	Total Petroleum Hydrocarbon performed by GC-FID.	0.5 mg/L
Faecal Coliforms	APHA 9222D:Online Edition	1 cfu/100ml
E. coli	APHA 9222I:Online Edition	1 cfu/100mL
Sample Filtration	Sample filtered through 0.45 micron filter following APHA Online Edition Method 3030B.	n/a

Unless otherwise stated, all tests are performed in Wellington.

The laboratory is not responsible for the information provided by the customer which can affect the validity of the results.

"<" means that no analyte was found in the sample at the level of detection shown. Detection limits are based on a clean matrix and may vary according to individual sample.

g/m3 is the equivalent to mg/L and ppm.

Samples will be retained for a period of time, in suitable conditions appropriate to the analyses requested.

This laboratory is accredited by International Accreditation New Zealand and its reports are recognised in all countries affiliated to the International Laboratory Accreditation Co-operation Mutual Recognition Arrangement (ILAC-MRA). The tests reported have been performed in accordance with our terms of accreditation, with the exception of tests marked "not an accredited test", which are outside the scope of this laboratory's accreditation.

This report may not be reproduced except in full without the written approval of this laboratory.



Report Released By
Rob Deacon



Wellington
85 Port Road, Seaview
Lower Hutt 5045
Phone: (04) 576-5016

Rolleston
43 Detroit Drive
Rolleston 7675
Phone: (03) 343-5227

Dunedin
16 Lorne Street
South Dunedin 9012
Phone: (03) 972-7963

Page 3 of 3
Report Number: 20/52258-1 ELS

02 October 2020 16:03:38